# Victaulic® Transition Couplings Style 307





Patented

# 1.0 PRODUCT DESCRIPTION

## **Available Sizes**

• 3 - 12"/DN80 - DN300

# **Maximum Working Pressure**

• Up to 500 psi/3450 kPa

# **Application**

- Provides direct transition from cut or roll grooved IPS pipe to AWWA ductile iron pipe.
- Provides a rigid pipe joint designed to restrict axial or angular movement.

### **Pipe Material**

• Steel and ductile iron.

# 2.0 CERTIFICATION/LISTINGS







### NOTE

Refer to Victaulic <u>publication 10.01</u> for details

ALWAYS REFER TO ANY NOTIFICATIONS AT THE END OF THIS DOCUMENT REGARDING PRODUCT INSTALLATION, MAINTENANCE OR SUPPORT.

System No.	Location	
Submitted By	Date	

Spec Section	Paragraph	
Approved	Date	



### 3.0 SPECIFICATIONS - MATERIAL

**Housing:** Ductile iron conforming to ASTM A536, Grade 65-45-12. Ductile iron conforming to ASTM A395, Grade 65-45-15, is available upon special request.

### Housing Coating: (specify choice)

Standard: Orange enamel.

On request the following are available:

Alkyd-phenolic primer (1.5 mil).

Coal tar epoxy coating (3 mils).

Optional: Organic zinc primer (3 mils).

Optional: Bituminous coating.
Optional: Hot dipped galvanized.

### NOTE

• Others available, contact Victaulic.

### Gasket: (specify choice1)

### Grade "M" Flush-Seal™

Halogenated Butyl (Brown color code). Temperature range –20°F to +200°F/–29°C to +93°C. Specially compounded to conform to ductile pipe surfaces. Recommended for water service within the specified temperature range plus a variety of dilute acids, oil-free air, and many chemical services. UL classified in accordance with ANSI/NSF 61 for cold +86°F/+30°C potable water service. NOT RECOMMENDED FOR PETROLEUM SERVICES.

### Grade "S" Flush-Seal™

Nitrile (Red color code). Temperature range –20°F to +180°F/–29°C to + 82°C. Specifically compounded to conform to ductile pipe surfaces. Recommended for petroleum products, air with oil vapors, vegetable and mineral oils within the specified temperature range; except hot air over +140° F/+60° C and water over +150° F/+66°C. NOT RECOMMENDED FOR HOT WATER SERVICES.


Services listed are General Service Guidelines only. It should be noted that there are services for which these gaskets are not compatible. Reference should always be made to the latest <u>Victaulic Seal Selection Guide</u> for specific gasket service guidelines and for a listing of services which are not compatible.

# Bolts/Nuts: (specify choice<sup>2</sup>)

**Standard:** Carbon steel oval neck track bolts meeting the mechanical property requirements of ASTM A449 (imperial) and ISO 898-1 Class 9.8 (M10-M16) Class 8.8 (M20 and greater). Carbon steel hex nuts meeting the mechanical property requirements of ASTM A563 Grade B (imperial – heavy hex nuts) and ASTM A563M Class 9 (metric – hex nuts). Track bolts and hex nuts are zinc electroplated per ASTM B633 ZN/FE5, finish Type III (imperial) or Type II (metric).

**Optional (imperial):** Stainless steel oval neck track bolts meeting the mechanical property requirements of ASTM F593, Group 2 (316 Stainless Steel), condition CW. Stainless steel heavy nuts meeting the mechanical property requirements of ASTM F594, Group 2 (316 stainless steel), condition CW, with galling reducing coating.

<sup>2</sup> Optional bolts/nuts are available in imperial size only.




Exaggerated for Clarity



#### **DIMENSIONS** 4.0

# Style 307



Pipe Size		Mating Pipe Actual Size		Bolt/Nut <sup>3</sup>		Dimensions		Weight	
Nominal	Actual Outside Diameter	IPS Steel	AWWA Ductile	Qty.	Size	X	Υ	Z	Approximate (Each)
inches DN	inches	inches	inches		inches	inches mm	inches mm	inches mm	lb ka
3	mm 3.960	mm 3.500	mm 3.96			5.50	7.38	2.07	kg 6.0
DN80	100.6	88.9	100.6	2	½ x 2¾	140	187	53	2.7
4	4.800	4.500	4.80	2	2 ½ x 3 ¼	6.38	9.00	2.19	8.0
DN100	121.9	114.3	121.9			162	229	56	3.6
6	6.900	6.625	6.90	2	5/8 x 3 1/4	8.44	11.13	2.31	9.0
DN150	175.3	168.3	175.3	2		214	283	59	4.1
8	9.050	8.625	9.05		<sup>3</sup> / <sub>4</sub> x 5	11.00	13.88	2.63	18.0
DN200	229.9	219.1	229.9	2		279	353	67	8.2
10	11.100	10.750	11.10	1	2 7/8 x 6½	13.13	16.50	2.63	22.0
DN250	281.9	273.0	281.9	2		334	419	67	10.0
12	13.200	12.750	13.20	2	7/0 61/	15.38	18.94	2.63	31.0
DN300	335.3	323.9	335.3		7/8 x 6½	391	481	67	14.1

Metric thread size bolts are available (color coded gold) for all coupling sizes upon request. Contact Victaulic for details.

# 5.0 PERFORMANCE

# Style 307

victaulic.com

Si	ze	Pipe End Separation			
Nominal	Actual Outside Diameter	Allowable	Maximum Joint Working Pressure <sup>4</sup>	Maximum Permis. End Load <sup>4</sup>	
inches	inches	inches	psi	lb	
DN	mm	mm	kPa	N	
3	3.960	0.03	500	4810	
DN80	100.6	1	3450	21405	
4	4.800	0.06	500	7950	
DN100	121.9	2	3450	35377	
6	6.900	0.06	400	13780	
DN150	175.3	2	2750	61321	
8	9.050	0.03	400	23370	
DN200	229.9	1	2750	103997	
10	11.100	0.03	350	31760	
DN250	281.9	1	2410	141332	
12	13.200	0.03	350	44680	
DN300	335.3	1	2410	198826	

Working Pressure and End Load are total, from all internal and external loads, based on AWWA class 53 ductile iron pipe radius cut grooved in accordance with ANSI/AWWA C-606 specifications and ANSI standard wall carbon steel pipe cut or roll grooved in accordance with Victaulic specifications. Contact Victaulic for performance on other pipe.

23.03 1655 Rev F Updated 10/2018 © 2018 Victaulic Company. All rights reserved. 3

#### **NOTIFICATIONS** 6.0

- WARNING: FOR ONE TIME FIELD TEST ONLY, the Maximum Joint Working Pressure may be increased to 1 ½ times the figures shown.
- For field installation only. Style 307 Transition couplings are essentially rigid and do not permit expansion/contraction.

# WARNING













- · Read and understand all instructions before attempting to install, remove, adjust, or maintain any Victaulic piping products.
- . Depressurize and drain the piping system before attempting to install, remove, adjust, or maintain any Victaulic piping products.
- . Wear safety glasses, hardhat, and foot protection.

Failure to follow these instructions could result in death or serious personal injury and property damage.

#### 7.0 REFERENCE MATERIALS

10.01: Regulatory Approval Reference Guide

23.01: AWWA Ductile Iron Pipe - Grooved System

23.02 Style 31 Grooved Coupling

29.01: Terms and Conditions/Warranty

I-300: Field Installation Handbook: AWWA Products

I-ENDCAP: Victaulic® End Caps Installation Instructions

### User Responsibility for Product Selection and Suitability

Each user bears final responsibility for making a determination as to the suitability of Victaulic products for a particular end-use application, in accordance with industry standards and project specifications, as well as Victaulic performance, maintenance, safety, and warning instructions. Nothing in this or any other document, nor any verbal recommendation, advice, or opinion from any Victaulic employee, shall be deemed to alter, vary, supersede, or waive any provision of Victaulic Company's standard conditions of sale, installation guide, or this disclaimer.

## Intellectual Property Rights

No statement contained herein concerning a possible or suggested use of any material, product, service, or design is intended, or should be constructed, to grant any license under any patent or other intellectual property right of Victaulic or any of its subsidiaries or affiliates covering such use or design, or as a recommendation for the use of such material, product, service, or design in the infringement of any patent or other intellectual property right. The terms "Patented" or "Patent Pending" refer to design or utility patents or patent applications for articles and/or methods of use in the United States and/or other countries.

### Note

This product shall be manufactured by Victaulic or to Victaulic specifications. All products to be installed in accordance with current Victaulic installation/assembly instructions. Victaulic reserves the right to change product specifications, designs and standard equipment without notice and without incurring obligations.

### Installation

Reference should always be made to the Victaulic installation handbook or installation instructions of the product you are installing. Handbooks are included with each shipment of Victaulic products, providing complete installation and assembly data, and are available in PDF format on our website at www.victaulic.com.

### Warranty

Refer to the Warranty section of the current Price List or contact Victaulic for details.

### Trademarks

Victaulic and all other Victaulic marks are the trademarks or registered trademarks of Victaulic Company, and/or its affiliated entities, in the U.S. and/or other countries.



